



Building Inspection Department

OFFICES:**CENTRAL:**

180 D N. 3rd Avenue
Williams Lake, B.C. V2G 2A4
Phone: (250) 392-3351
Toll Free: 1-800-665-1636
Fax: (250) 392-2812

SOUTH:

Unit 3 -170 Cedar Avenue
P.O. Box 2260
100 Mile House, B.C. V0K 2E0
Phone: (250) 395-3838
Fax: (250) 395-4898

NORTH:

102 - 410 Kinchant Street
Quesnel, B.C. V2J 7J5
Phone: (250) 992-7400
Fax: (250) 992-7414

Completion/Final Inspection

Report Issued: August 22, 2024
Inspection Result: **Passed**

Permit Number: **PR20200554**

Issuance Date: July 21, 2005
Property Address: 3561 CANIM-HENDRIX LAKE
To Construct: New Structure

On this day we have inspected your construction for **Completion/Final** and we find the following result of the inspection. If there are any questions, please call the inspector at the address below.

Notes: Dec 10/20 deficiencies completed

- Guards installed on deck where over 600mm from grade
- interior stair infilled and inaccessible
- interior finishes still being installed
- code compliant at time of inspection

ok to close file

Deficiencies:**CONDITIONS:**

Inspector's Information: